


"Overzicht meetresultaten systeemwand met Viltafwerking"

HERTZ	125	250	500	1000	2000	4000
Soundfelt 50	0,12	0,21	0,52	0,87	0,96	0,77
Soundfelt 90	0,18	0,34	0,60	0,75	0,76	0,77
Soundfelt 90 Lux	0,33	0,51	0,68	0,75	0,69	0,78
Soundfelt 200	0,5	0,71	0,87	0,73	0,81	0,83



TYPE	Alphaw.	Klasse
Soundfelt 50	0,50	D
Soundfelt 90	0,60	C
Soundfelt 90 Lux	0,70	C
Soundfelt 200	0,80	B

Meting te KU Leuven  
 Verboden gedeeltelijk te reproduceren zonder toestemming